City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 8/10/90

Report From:
- [x] Citizen
- [ ] Fire Dept
- [ ] Sewer Maintenance
- [ ] Other

Received By: R. SCHAEFER
Referred To: R. LYMAN
Date of Incident: 8/10/90

Complainant Information:
Name Geoffrey Butler
Address 1550-B E. Battlefield
Phone 881-0340

Responsible Party Information:
Name J. PARRINO'S
Address 1550-L E. Battlefield
Phone 882-1808

Directions (if needed)

Possible contamination of:
- [ ] soil
- [ ] groundwater
- [ ] surface water what body?
- [ ] other

Other Pertinent Information SERIOUS OIL AND GREASE problem from J. PARRINO'S

Who to contact:

[ ] DNR 417-883-4033	[ ] Bob Schaefer	[ ] Sewer Const
[ ] DNR 314-634-2436	[ ] CU 831-8320	[ ] Chemtrec 800-424-9300
[ ] EPA 913-236-3378	[ ] Street Dept	[ ] DOT
[ ] Fire Dept 864-1719	[x] Health Dept	[ ] NRC 312-790-5500
[ ] Police Dept 864-1719	[ ] Sewer Maint	[ ] Other

Details of Incident: OIL AND GREASE PROBLEM IN SEWER. WYO MAP Y-12.

Action needed: INSPECT, CONSULT, + SAMPLE.

On 8-21-90 Karen Chandler & I inspected Parrino's Sample M.H. (This M.H. actually serves the whole Galleria shopping center) We saw very little evidence of heavy grease. There was a small coating (film) on the sides of their private line. We looked at the above & below sanitary sewer MH's. We did not find any evidence of heavy grease in the

1550-L E. Battlefield

Investigation Results

Sanitary Sewer MH Below Farlings. We contacted Chuck Griffin (Sewer Maintenance Supervisor) to see when the last time when the City has maintained the sanitary sewer which serves Farlings. Mr. Griffin found no record that this section of line had ever been maintained. Mr. Griffin told one of his maintenance people to flush the line. Timer Bouse flushed this section of line and found no grease. Since the City's sewer line does not appear to be affected by this problem, I see no action that we can take at this time. I will contact the Health Dept. About this problem so they can take any appropriate action, if need be.

4-12

ADDITION

21

MH 4+00
T=1315.20
FL=1310.44 S
=1307.98 N

PLUGGED @ MAIN
8' N OF M.H.-21

75C
11

74.10

74.00

77.05

ROAD

30

32

23

22

8" C.I.P.

MH 6+40 N
0+00 E
T=1315.20
FL=1311.42 E
=1311.40 N

M.H.(A-1) 0+00 E f W
T=1315.33
FL-1312.33

1+60

8" P.V.C.

M.H.(A-1)
FL-1312.13

3+07

MH 4+13
T=1319.20
FL=1314.82 E & W

5+41

6+22

BATTLEFIELD

1

2

3

75A
11

5

6

7

J. Parrino's

M.H.(A-2)
FL-1313.50

0+24

M.H.(C-1)
FL-1314.35

3+22

2+22

8

1+30 E
3+17 N

RAYNELL ST

255'

145'

8" P.V.C.

0+99 E
0+00 N

1+25

1+46

0+27

2+10

2+08

1+17

SOUTH ADD.

43

L.H. & M.H. N
LAST NUMBE

19

18

17

16

15

14

13

12

Y