City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 9/25/91

Report From:
- ☐ Citizen
- ☐ Fire Dept
- ☒ Sewer Maintenance CHUCK G.
- ☐ Other

Received By: R. LYMAN
Referred To: G. PABST
Date of Incident: 9/25/91

Complainant Information:
Name
Address
Phone

Responsible Party Information:
Name MANDARIN INN
Address 706 E. Battlefield
Phone 882-8181

Directions (if needed)

Possible contamination of: ☐ soil ☐ groundwater ☐ surface water what body? ☐ other

Other Pertinent Information

Who to contact:

☐ DNR 417-883-4033	☐ Bob Schaefer	☐ Sewer Const
☐ DNR 314-634-2436	☐ CU 831-8320	☐ Chemtrec 800-424-9300
☐ EPA 913-236-3378	☐ Street Dept	☐ DOT
☐ Fire Dept 864-1719	☐ Health Dept	☐ NRC 312-790-5500
☐ Police Dept 864-1719	☐ Sewer Maint	☐ Other

Details of Incident: GREASE IN SANITARY SEWER BEHIND FACILITY. WAS NOT STOPPED UP, but did HAVE A BUILDUP. SEWER MAINTENANCE DID OBSERVE SAMPLING MANHOLE AND IT LOOKED RATHER CLEAN. INSPECTIONS A FEW YEARS AGO INDICATED THE USE OF LARGE AMOUNTS OF HOT WATER USED TO KEEP GREASE TRAP CLEAN.

Action needed: INSPECT AND SAMPLE AS NECESSARY.

Y-11 Between MHB-3 & MHB-2

706 E. Battlefield.

Investigation Results

I Reviewed this complaint with Chuck Griffin on 12-2-91 to see if there had been any further problem. He said that there were no calls of blockages nor did his records ever show any blockages in the sanitary sewer. He indicated that they found grease on their routine maintenance. He suggested we wait until the line is cleaned again & then go from there.

Gene Pabst