City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 9/5/91

Report From:
- [x] Citizen
- [ ] Fire Dept.
- [ ] Public Information Office
- [ ] Health Department
- [ ] Other

Received By: JULIE
Referred To: S. SHORT
Date of Incident: 9/5/91

Complainant Information:
Name DEE (MANAGER)
Address 2185 S. Campbell
Phone 881-9928

Responsible Party Information:
Name UNKNOWN
Address
Phone

Directions (if needed): TOP OF THE RAI LOUNGE

Possible contamination of:
- [ ] soil
- [ ] groundwater
- [ ] surface water what body?
- [ ] other

Other pertinent information:
PAINT THINNER ODOR IN BUILDING

Who to contact:
- [ ] DNR 417-837-6950
- [ ] DNR 314-634-2436
- [ ] EPA 913-236-3778
- [ ] Fire Dept. 864-1719
- [ ] Police Dept. 864-1719
- [ ] Bob Schaefer
- [ ] CU 831-8320
- [ ] Street Dept.
- [ ] Health Dept.
- [ ] Sewer Maintenance
- [ ] Sewer Construction
- [ ] Chemtrec 1-800-424-9300
- [ ] DOT
- [ ] NRC 1-800-424-8802
- [ ] Other

Details of incident: STRONG SOLVENT ODOR IN BUILDING. STARTED AT 3:00 PM CALLED AT 4:00. FIRE DEPARTMENT (MIKE LOGUE) AND PUMPER TRUCK, PLUS CU GAS RESPONDED.

Action needed: CHECKED FLOOR DRAIN, TRAPS, ETC., NEARBY MANHOLES AND UPSTREAM MANHOLES AND INSPECTED CLOSE BY PROBABLE SOURCES.

(over) ADDRESS 2185 S. Campbell

Investigation Results

TESTED 2% L.E.L M.H. 11, 0% M.H. 12, ~~[illegible]~~ W & E MAP V-9, M.H. 20. 2% M.H. 17, 1%, M.H. 16, 0%, W & E MAP V-10. USED EXOTOX 50.

ADVISED MANAGER TO ADD WATER TO FLOOR DRAIN BEHIND BAR.

CHECKED ALLIED PAINT NEXT. NO APPARENT PROBLEM WAS OBSERVED.

AREA SHOULD BE CHECKED IN FUTURE AS MANAGER OF BAR INDICATED IT OCCURRED AT LEAST 5 TIMES DURING LAST 30 DAYS.

NOTE BIOREMEDIATION PROJECT FOR CONTAMINATED SOIL AT FORMER SERVICE STATION AT McGEE + CAMPBELL