City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 3/11/91

Report From:
- [x] Citizen
- [ ] Fire Dept
- [ ] Sewer Maintenance
- [ ] Other

Received By: LYNN
Referred To: CARSON/SHORT
Date of Incident:

Complainant Information:
Name LLOYD'S CLEANERS
Address 3348 S. CAMPBELL
Phone

Responsible Party Information:
Name
Address
Phone

Directions(if needed)

Possible contamination of:
- [ ] soil
- [ ] groundwater
- [ ] surface water what body?
- [ ] other

Other Pertinent Information METHANE/SEWER ODOR IN BUILDING

Who to contact:

[ ] DNR 417-883-4033	[ ] Bob Schaefer	[ ] Sewer Const
[ ] DNR 314-634-2436	[ ] CU 831-8320	[ ] Chemtrec 800-424-9300
[ ] EPA 913-236-3378	[ ] Street Dept	[ ] DOT
[ ] Fire Dept 864-1719	[ ] Health Dept	[ ] NRC 312-790-5500
[ ] Police Dept 864-1719	[ ] Sewer Maint	[ ] Other

Details of Incident:

Action needed:

3348 S. Campbell

Investigation Results

SAMPLED M.H. S6 S7 S8 AND M.H. (A-6). ALL OF L.E.L. (Z-9). CONTACTED LLOYDS EMPLOYEE, AND INSPECTED BUILDING AT 3348 S. CAMPBELL. NOTED TWO FLOOR DRAINS, ONE IN GROOM CLOSET AND ONE IN [redacted] RESTROOM. ADVISED EMPLOYEE TO ADD WATER TO DRAINS MONTHLY. IT APPEARED THE DRAIN IN THE RESTROOM WAS DRY. M.H. A-6 IS FULL OF DIRT. WILL ADVISE SEWER MAINT.