3:50
3:~~5~~0
1 hr.

75811
829
13

City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 4/27/89

Report From:
- [x] Citizen
- [ ] Fire Dept
- [ ] Sewer Maintenance
- [ ] Other_____

Received By: W. LATIMER
Referred To: B. CARSON
Date of Incident: UNKNOWN

Complainant Information:
Name_____
Address_____
Phone_____

Responsible Party Information:
Name McDONALDS
Address 4101 S. Campbell
Phone 887-4101

Directions(if needed)_____

Possible contamination of:
- [x] soil
- [ ] groundwater
- [x] surface water
- [ ] other_____

what body? STORM DITCH ON EAST SIDE of property

Other Pertinent Information_____

Who to contact:

[ ] DNR 417-883-4033	[ ] Bob Schaefer	[ ] Sewer Const
[ ] DNR 314-634-2436	[ ] CU 831-8320	[ ] Chemtrec 800-424-9300
[ ] EPA 913-236-3378	[ ] Street Dept	[ ] DOT
[ ] Fire Dept 864-1719	? [ ] Health Dept	[ ] NRC 312-790-5500
[ ] Police Dept 864-1719	[ ] Sewer Maint	[ ] Other_____

Details of Incident: OBSERVED A POOL (20+ GALS) OF WATER AT TERMINATION OF STORM WATER PIPE LOCATED AT SE CORNER OF PROPERTY. DARK WATER APPEARED TO BE CONTAMINATED WITH OIL FROM LOT WASHING.

Action needed: OIL/WATER SEPERATOR WOULD REMOVE OIL. THIS MAY BE PART OF A STORMWATER RETENTION BASIN, AND COULD BE PUMPED BY SEPTIC TRUCK.

4/27/89 Stephen Smith

4101 S. Campbell

3:50
3:40
1 hr.

75811
829
13

City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 4/27/89

Report From:
- [x] Citizen
- [ ] Fire Dept
- [ ] Sewer Maintenance
- [ ] Other_____

Received By: W. LATIMER
Referred To: B. CORSON
Date of Incident: UNKNOWN

Complainant Information:
Name_____
Address_____
Phone_____

Responsible Party Information:
Name McDONALDS
Address 4101 S. Campbell
Phone 887-4101

Directions(if needed)_____

Possible contamination of:
- [x] soil
- [ ] groundwater
- [x] surface water — what body? STORM DITCH ON EAST SIDE of PROPERTY
- [ ] other_____

Other Pertinent Information_____

Who to contact:

? [ ] DNR 417-883-4033	[ ] Bob Schaefer	[ ] Sewer Const
[ ] DNR 314-634-2436	[ ] CU 831-8320	[ ] Chemtrec 800-424-9300
[ ] EPA 913-236-3378	[ ] Street Dept	[ ] DOT
[ ] Fire Dept 864-1719	? [ ] Health Dept	[ ] NRC 312-790-5500
[ ] Police Dept 864-1719	[ ] Sewer Maint	[ ] Other_____

Details of Incident: OBSERVED A POOL (20+ GALS) OF WATER AT TERMINATION OF STORM WATER PIPE LOCATED AT SE CORNER OF PROPERTY. DARK WATER APPEARED TO BE CONTAMINATED WITH OIL FROM LOT WASHING.

Action needed: OIL/WATER SEPERATOR WOULD REMOVE OIL. THIS MAY BE PART OF A STORMWATER RETENTION BASIN, AND COULD BE PUMPED BY SEPTIC TRUCK.
4/27/89 Stephen Smith

4101 S. CAMPBELL