CITY of SPRINGFIELD

NOV 16 1998

November 13, 1998

Mr. David O'Dell
Greene County Building Regulations
940 Boonville
Springfield, MO 65802

RE: Sanitary Sewer Review
CTI Trucking, Inc. (New Facility)
4800 Block W. Maple

Dear Mr. O'Dell:

Enclosed is the review copy of the Building Plans with comments enclosed. The following comments were made by Mr. Bob Schaefer.

Not Approved.

a. Private sewer lateral across other property to the east is not allowed.
b. Must design a public sanitary sewer extension from Miller Avenue to this property and submit plans to Springfield Public Works Department for approval.
c. Must build public sanitary sewer extension after plans are approved and pay inspection fee for City construction inspection of the public line.
d. After public sewer is completed must pay sewer impact fee prior to connection.
e. Storage Room on sheet P077.20, needs dike around so spillage or leakage cannot enter the floor drain.
f. Need an additional sheet P077.31.

Carl W. Knuckles, P.E.
Professional Engineer

cc: Bob Schaefer
Ed Malter
King Coltrin
Randy Lyman

DEPARTMENT OF PUBLIC WORKS
840 BOONVILLE AVENUE, P.O. BOX 8368 SPRINGFIELD, MISSOURI 65801-8368
(417) 864-1900

4700 Block W. Farm Rd. 130