City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 5/22/89

Report From:
- ☐ Citizen
- ☐ Fire Dept
- ☐ Sewer Maintenance
- ☑ Other Police Dept.

Received By: B. Corson
Referred To: Steve Short
Date of Incident: 5/22/89

Complainant Information:
Name
Address
Phone

Responsible Party Information:
Name Pemco - Barrell Franklin Lew Hawks
Address Nettleton + Florida
Phone 863-6998

Directions (if needed)

Possible contamination of: ☑ soil ☐ groundwater
☑ surface water what body?
☐ other

Other Pertinent Information KMNO4 - spill

Who to contact:

☐ DNR 417-883-4033	☐ Bob Schaefer	☐ Sewer Const
☐ DNR 314-634-2436	☐ CU 831-8320	☐ Chemtrec 800-424-9300
☐ EPA 913-236-3378	☐ Street Dept	☐ DOT
☐ Fire Dept 864-1719	☐ Health Dept	☐ NRC 312-790-5500
☐ Police Dept 864-1719	☐ Sewer Maint	☐ Other

Details of Incident: Contacted Lew Hawks, at scene, old Ozark Hardwoods Plant. Company packages lava stone, and also treats lava stone with KMNO4. Roof leaked, filled a sump (not tributary to sanitary sewer) which was automatically pumped to 1,000 gallon liquid KMNO4 mix tank. Tank overflowed, and flowed out of building to the North. When I arrived on scene, there were berms of top soil constructed to contain the (back)

Action needed:
None by this office

1500 W. Florida

Investigation Results

SPILL. I DIDN'T OBSERVE ANY DISCHARGE TO NATURAL WATERS. I DID GIVE THE COMPANY PERMISSION TO PUMP THE LIQUID TO A SANITARY SEWER MANHOLE ON THEIR PROPERTY.

THE COMPANY SUPPLIES LAVA STONE TO WASH BLUE JEANS. ONE PRODUCT IS LAVA STONE TREATED WITH KMNO4 IN A DRUM CONTAINER. THERE NORMALLY IS NO DISCHARGE TO THE SANITARY SEWER.