City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 7/12/90

Report From:
- ☐ Citizen
- ☐ Fire Dept
- ☐ Sewer Maintenance
- ☒ Other JUDY DILL - DNR

Received By: R. LYMAN
Referred To: G. PABST
Date of Incident: ongoing

Complainant Information:
Name UNKNOWN
Address
Phone
Directions(if needed)

Responsible Party Information:
Name HENDRICK DIESEL
Address 2643 E. KEARNEY
Phone 831-0825

Possible contamination of: ☒ soil ☒ groundwater
☐ surface water what body?
☒ other STM. TRNY SEWER

Other Pertinent Information

Who to contact:

☐ DNR 417-883-4033	☐ Bob Schaefer	☐ Sewer Const
☐ DNR 314-634-2436	☐ CU 831-8320	☐ Chemtrec 800-424-9300
☐ EPA 913-236-3378	☐ Street Dept	☐ DOT
☐ Fire Dept 864-1719	☐ Health Dept	☐ NRC 312-790-5500
☐ Police Dept 864-1719	☐ Sewer Maint	☐ Other

Details of Incident: DNR RECEIVED COMPLAINT ON DUMPING OF WASTE OIL, JUDY DILL HAS INVESTIGATED AND FOUND SPILLAGE AND PROBABLY SEVERAL DRUMS THAT SHOULD HAVE BEEN REMOVED FROM PREMISES BY NOW. COMPLAINTANT ALSO SAID they DUMP PARTS CLEANERS, CARBURETOR CLEANER, AND SOLVENTS DOWN DRAINS IN BUILDING. MS. DILL SAID SHE OBSERVED "SAFETY KLEEN" PARTS WASHER AT THIS FACILITY.

Action needed: MAKE INSPECTION AND SEE IF EVIDENCE OF DUMPING TO SEWER, REQUIRE SAMPLING & ANALYSE IF NECESSARY.

(over)

2643 E. Kearney

Investigation Results

7-24-90 I went to Hendricks Diesel & pulled A sAmple from SAmpling M.H. It Appeared okAy. I went inside & tAlked to Bob Hendrick's, shop foremAn, And he said they do not dump solvents down the drAin. I did An inspection on the shop Area. They clean pArts with Safety Kleen Solvent & Safety Kleen picks it up. They Also do steAm cleAning which goes to the SAnitAry sewer through A sump (inside). Sump Appeared to be functioning properly with the elbow on the discharge line in place. They do hAve A hot tAnk but the very rArely use it. They Are thinking About doing AwAy with the hot tAnk.

I could not reAlly find AnythIng out of the ordinAry (3:00 P.M.)

Gene Palot