City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 2/21/89

Report From:
- [x] Citizen
- [ ] Fire Dept
- [ ] Sewer Maintenance
- [ ] Other

Received By: Joe Harmon
Referred To: Steve Shore
Date of Incident: 2/21/89

Complainant Information:
Name Airborne Exp.
Address 4800 W. Kearney
Phone 869-0879
Directions (if needed)

Responsible Party Information:
Name Larry Smith
Address
Phone

Possible contamination of:
- [ ] soil
- [ ] groundwater
- [ ] surface water what body?
- [x] other Air & building

Other Pertinent Information H_2S + sewer gases venting out of sanitary sewer into building as well as neighborhood.

Who to contact:

[ ] DNR 417-883-4033	[ ] Bob Schaefer	[ ] Sewer Const
[ ] DNR 314-634-2436	[ ] CU 831-8320	[ ] Chemtrec 800-424-9300
[ ] EPA 913-236-3378	[ ] Street Dept	[ ] DOT
[ ] Fire Dept 864-1719	[ ] Health Dept	[ ] NRC 312-790-5500
[ ] Police Dept 864-1719	[ ] Sewer Maint	[ ] Other

Details of Incident: Strong odor (H_2S) in area. Bad odor in men's restroom as well as outside building. Checked M.H. in their yard. Strong odor also. Checked manhole at termination of Willard Lift same odor. Did not observe odor 2nd manhole upstream of Lift Lift.

Action needed: We need to smoke test the building to determine if there is a loss of integrity in their plumbing. It appears the odor is from the Willard Lift so the plant should be notified to increase chlorine dosage.

4800 W. Kearney