City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 9/5/89

Report From:
- [x] Citizen
- [ ] Fire Dept
- [ ] Sewer Maintenance
- [ ] Other

Received By: R. LYMAN
Referred To:
Date of Incident: 9/5/89

Complainant Information:
Name UNKNOWN
Address
Phone

Responsible Party Information:
Name CRYSTAL CUBE ICE CO.
Address 2530 E. Livingston
Phone 866-2133

Directions(if needed)

Possible contamination of:
- [ ] soil
- [ ] groundwater
- [ ] surface water what body?
- [ ] other

Other Pertinent Information

Who to contact:

[ ] DNR 417-883-4033	[ ] Bob Schaefer	[ ] Sewer Const
[ ] DNR 314-634-2436	[ ] CU 831-8320	[ ] Chemtrec 800-424-9300
[ ] EPA 913-236-3378	[ ] Street Dept	[ ] DOT
[ ] Fire Dept 864-1719	[ ] Health Dept	[ ] NRC 312-790-5500
[ ] Police Dept 864-1719	[ ] Sewer Maint	[ ] Other

Details of Incident: WATER DISCHARGES DOWN STREET CONTINUOUSLY. HARD TO KEEP CAR CLEAN. AFRAID WILL FREEZE THIS WINTER.

Action needed: MAKE INSPECTION AND DIRECT TO DISCHARGE TO SANITARY SEWER IF APPROPRIATE

9-7-89 Karen Chandler & I talked to the plant mgr. About the problem on 9-7-89 at 10:00 A.M. He showed us the problem. His pressure main was plugged & had the pump discharging onto the ground. He said that he has had a plumber out but could not find blockage because he did not know where the pressure line was located. I talked (called on the telephone) Mr. Bob Schaefer about the pressure line location. Bob said that they should contact Jim Hedges Construction, since the put in the pressure lines. I told the plant mgr. to contact Hedges. When we returned to the office, Karen referred the matter to the Health Dept.

2530 E. Livingston Gene Pabst