City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 6/16/89

Report From:
- ☐ Citizen
- ☐ Fire Dept
- ☐ Sewer Maintenance
- ☐ Other_____

Received By:_____
Referred To:_____
Date of Incident: 6/16/89

Complainant Information:
Name_____
Address_____
Phone_____

Responsible Party Information:
Name Hudson Foods
Address N. MAIN
Phone_____

Directions(if needed)_____

Possible contamination of: ☐ soil ☐ groundwater
☑ surface water what body?_____
☐ other_____

Other Pertinent Information ~~[illegible]~~

Who to contact:

☑ DNR 417-883-4033	☐ Bob Schaefer	☐ Sewer Const
☐ DNR 314-634-2436	☐ CU 831-8320	☐ Chemtrec 800-424-9300
☐ EPA 913-236-3378	☐ Street Dept	☐ DOT
☐ Fire Dept 864-1719	☐ Health Dept	☐ NRC 312-790-5500
☐ Police Dept 864-1719	☐ Sewer Maint	☐ Other_____

Details of Incident: I OBSERVED BLOOD IN DOUBLE BOX AT JORDAN CREEK. CALLED GENE + KAREN FOR HELP AS HAD TO CRAWL STORM BOX TO DETERMINE SOURCE. OBSERVED SOURCE AS 18" VCP PIPE FROM MAIN STREET DROP INLET. DETERMINED HUDSON FOODS TRUCK HAD LOST IT EARLY A.M. I CONTACTED D.M. PRICE AND TOLD HIM TO REPORT IT TO THE MO D.N.R.

Action needed: NO RECOVERY POSSIBLE DUE TO C.U. FLUSHING UPSTREAM. OBSERVED NO DISTRESS OF AQUATIC LIFE. WILL CHECK AGAIN MONDAY.

GEORGE PARSONS, MO. D.N.R., CALLED HUDSON DID REPORT TO HIM.

501 N. MAIN

City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 7/24/91

Report From:
- [x] Citizen
- [ ] Fire Dept.
- [ ] Public Information Office
- [ ] Health Department
- [ ] Other

Received By: Julie
Referred To: Bob/Steve
Date of Incident: 7/24/91 10:30

Complainant Information:
Name Charles Rich
Address 1022 Wall
Phone 866-4364

Responsible Party Information:
Name Hudson Foods
Address Main Street
Phone 862-3773

Directions (if needed):

Possible contamination of:
- [ ] soil
- [ ] groundwater
- [x] surface water what body? Jordan Cr.
- [ ] other Wall St. Storm Sew.

Other pertinent information:

Who to contact:
- [ ] DNR 417-837-6950
- [ ] DNR 314-634-2436
- [ ] EPA 913-236-3778
- [ ] Fire Dept. 864-1719
- [ ] Police Dept. 864-1719
- [ ] Bob Schaefer
- [ ] CU 831-8320
- [ ] Street Dept.
- [ ] Health Dept.
- [ ] Sewer Maintenance
- [ ] Sewer Construction
- [ ] Chemtrec 1-800-424-9300
- [ ] DOT
- [ ] NRC 1-800-424-8802
- [ ] Other

Details of incident: Mr. Rich called office to report Hudson Foods was discharging bloody water to Wall Street storm sewer.

Action needed: I saw no bloody discharge, but did observe foul parts on ground. Will send letter to Hudson.

(over) ADDRESS 501 N. Main

Investigation Results

ARRIVED AT Hudson Foods 10:40, AND CONTACTED Jim PRICE, MADE INSPECTION OF LOADING DOCK AREA WHERE WATER WAS STANDING ON CONCRETE PAD, BETWEEN ASPHALT STREET AND building AND offal DOOR AND UNLOADING DOOR. THERE WAS A DISCHARGE (< 2 gpm) FROM THE POOLED AREA. SOURCE OF THIS WATER WAS A ROOF LEADER LOCATED SOUTH OF THE ENTRANCE TO THE UNLOADING DOCK AND ROOF LEADER DRAINS LOCATED IN THE FOUNDATION, LOCATED WEST OF THE DOOR INTO THE PRETREATMENT ROOM. THE SOLE SOURCE OF DISHARGE WATER APPEARED TO BE STORMWATER. THERE WAS SEVERAL TURKEY PARTS (SKIN, GUTS, MEAT) ON THE ASPHALT STREET. THE WATER IN THE POOLED AREA LOOKED MUDDY TO ME AND NOT BLOODY. Jim AND I WALKED TO AN OPEN AREA WEST OF THE DEEP WELL WHERE REFRIGERATION LINES ARE LOCATED. THIS AREA IS TRIBUTARY TO THE DRAINS LOCATED WEST OF THE PRETREATMENT ROOM, DISCUSSED EARLIER. ICE ACCUMULATES ON THIS EQUIPMENT AND IS MELTED BY SPRAYING IT WITH A WATER HOSE. THIS WOULD BE UNCONTAMINATED WATER. THIS PLANT DOES HAVE A POTENTIAL FOR DEGRADING THE WATER QUALITY AND A INFLOW PROBLEM. INFLOW: A TRENCH HAS BEEN CUT IN THE CONCRETE, WEST OF THE UNLOADING ENTRANCE, ON THE ALLEY GRADE INTERCEPTING ALL FLOW COMING DOWN THE ALLEY IS NOW TRIBUTARY TO A DRAIN LEADING TO THE SUMP LOCATED ON THE EAST END OF THE UNLOADING DOCK. THIS DRAIN COULD TAKE SIGNIFICANT STORMWATER. Jim PRICE INDICATED THIS TRENCH IS SEVERAL YEARS OLD!

REINSPECTED 7/25 10:30. BLOOD IN GRAVEL PARKING LOT ACROSS FROM OFFAL ROOM. RUNOFF FROM ROOF DRAINS ALSO OBSERVED.

7/29 INSPECTED P.M. PUMP AT EAST END OF UNLOADING DOCK FAILED. OVERFLOW OUT OF ALLEY TRENCH DRAIN. OVERFLOW TO STORM. Randy Lyman OBSERVED. WILL REINSPECT.

7/30 NO DISCHARGE

SDS