City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 4/3/89

Report From:
- ☐ Citizen
- ☐ Fire Dept
- ☐ Sewer Maintenance
- ☐ Other GARY CORSON (C.U.)

Received By: S. Short
Referred To: G. Pabst
Date of Incident: 4/1/89 ?

Complainant Information:
Name
Address
Phone

Responsible Party Information:
Name CLINTON HYDE
Address 1030 E. Normal
Phone 865-7034

Directions (if needed)

Possible contamination of:
- ☐ soil
- ☐ groundwater
- ☐ surface water what body?
- ☑ other SANITARY SEWER

Other Pertinent Information

Who to contact:

☐ DNR 417-883-4033	☐ Bob Schaefer	☐ Sewer Const
☐ DNR 314-634-2436	☐ CU 831-8320	☐ Chemtrec 800-424-9300
☐ EPA 913-236-3378	☐ Street Dept	☐ DOT
☐ Fire Dept 864-1719	☐ Health Dept	☐ NRC 312-790-5500
☐ Police Dept 864-1719	☐ Sewer Maint	☐ Other

Details of Incident: GARY CORSON REPORTED THE PEOPLE AT 1030 E. NORMAL CALLED IN A GAS LEAK. THEIR INVESTIGATION REVEALED A GASOLINE NOT NATURAL GAS PROBLEM. HE INDICATED IT WAS DETECTABLE ON THE SECOND FLOOR. THE FIRE DEPARTMENT WAS CALLED.

Action needed: AT ABOUT 2:30 p.m. 4/3/89, MR. HYDE WAS CONTACTED. NO ~~PROBLEM~~ GASOLINE ODOR OBSERVED!

SEE BACK

1030 E. NORMAL

Investigation Results

I did discover a plug missing from a floor drain in the basement. Mr. Hyde was advised of the dangers of sewer vapors, etc., and informed him automotive stores have a rubber expandable plug that can be used to seal the opening. I did check several manholes in the area and did not detect any C.O. S.M.S.U. is the source, but did not detect anything there.

Note: This is an apartment house with six coed occupants, and the owner Mr. Hyde.

Clyde King was the C.O. serviceman who was called.