City of Springfield
Water Pollution Control Section
Pollution Complaint/Report Form

Date 4/2/89

Report From:
- ☐ Citizen
- ☑ Fire Dept
- ☐ Sewer Maintenance
- ☐ Other

Received By: S. Short
Referred To:
Date of Incident: 4/2/89

Complainant Information:
Name
Address
Phone

Responsible Party Information:
Name FAST + FRIENDLY, NAEGLER BROS
Address 1402 E. Republic 205 St. Louis
Phone 886-6060 869-2266

Directions (if needed)

Possible contamination of:
- ☑ soil
- ☐ groundwater
- ☐ surface water what body?
- ☐ other

Other Pertinent Information Asphalt and concrete lot.

Who to contact:

☐ DNR 417-883-4033	☐ Bob Schaefer	☐ Sewer Const
☐ DNR 314-634-2436	☐ CU 831-8320	☐ Chemtrec 800-424-9300
☐ EPA 913-236-3378	☐ Street Dept	☐ DOT
☐ Fire Dept 864-1719	☐ Health Dept	☐ NRC 312-790-5500
☐ Police Dept 864-1719	☐ Sewer Maint	☐ Other

Details of Incident: Dispenser knock-over resulted in a loss of 20 gallons of regular gas to the lot. My investigation indicated none had left their property as the Fire Dept. had put up sawdust dams on the lot.

Action needed: City provided sawdust (Fire Dept. called the service center). Chief Steve Strader wanted to know where to put "contaminated" sawdust at the service center. I advised that Mr. Naegler could put it in his dumpster after sweeping the material up. I also advised sweeping up the sawdust in a pile so that the gasoline vapors could ~~res~~ evaporate. I told Mr. Naegler he did not need to report the spill to the state as it did

1402 E. Republic

Investigation Results

NOT LEAVE his PROPERTY. GENE PABST will be ADVISED.