



**Administrative Ruling #2013-09  
Building Development Services  
Springfield, Missouri**

Pursuant to General Ordinance 6015, Sub-Article XIII, Chapter 36, Article III, Land Development Code, Section 36-1225 the following ruling is hereby made in order to clarify the current code language.

Code Reference: 2012 International Mechanical Code Section 307.2.1 and the 2012 International Residential Code Section M1411.3.

The wording in these sections stating "approved place of disposal" shall be clarified as follows. The crawl space of a structure shall NOT be an approved place of disposal. All condensate shall be disposed of by gravity means or by pumping, to the exterior of the structure or to a visible fixture or device.

Chris Straw, Director  
Building Development Services

12/2/13  
Date